#### Page 1 of 2




# TECHNICALSPECIFICATIONA2XS(FL)2Y 1x300RM/10576/132 (145)kVIEC 60840

### CONSTRUCTION (x)

- □ Round, stranded and compacted, aluminum conductor. Class 2
- Extruded semi-conducting conductor screen
- □ Insulation XLPE dry cured
- Extruded semi-conducting insulation screen
- □ Semi-conducting swelling tapes
- Metallic screen: copper wires screen and copper equalizing tapes
- □ Semi-conducting swelling tapes
- □ Longitudinal aluminum foil
- □ Sheath Black HDPE

## MARKING

TF KABLE, product name, date of manufacture, standard, meter marking



The picture is informative only – not in scale

### APPLICATION

- □ Laying in ground
  - (wet or dry locations)
- Laying in air
- □ Laying in ducts

# Highest permissible conductor temperature

- □ Continuous operation 90 °C
- □ Overload 105 °C
- □ Short circuit 250 °C ( duration max 5 s )

Laying is possible without any special measures at natural cable temperatures and ambient temperature not lower than -5°C, with Tele-Fonika supervising

DESCRIPTION	UNIT	DETAILS	
CONSTRUCTION DATA			
Conductor			
□ Material		Aluminum	
Number of wires	No	34	
Nominal cross sectional area	mm <sup>2</sup>	300	
Conductor diameter and tolerance	mm	20.0 -0.2 +0.3	
Min./Nom. thickness semi-conducting XLPE on conductor	mm	0.8 / 1.4	
Insulation thickness XLPE – nominal value	mm	18.5	
Insulation thickness: minimum at a point	mm	16.65	
Diameter over insulation – nominal	mm	59.8 <sup>±0.8</sup>	
Min./Nom. thickness semi-conducting XLPE on insulation	mm	0.6 / 1.0	
Thickness of semi-conducting swelling tape	No x mm	2 x ~ 0.35	
Metallic screen	mm <sup>2</sup>	105	
Copper wires	No x mm	66 x 1.44	
Copper equalizing tape	No x mm x mm	2 x 10 x 0.18	
Mean diameter over metallic screen	mm	65.6	
Thickness of semi-conducting swelling tape	No x mm	2 x ~ 0.35	
Thickness of aluminum foil	mm	0.2	
Nominal outer sheath thickness / min.	mm	3.3 / 2.7	
Approximate overall diameter completed cable (D <sub>e</sub> )	mm	74.0	
Weight of complete cable (approx.)	kg/km	5420	
DELIVERY DATA			
Diameter of wooden drum	m	2.8	3.2
□ type		28	32
Maximum length per drum	m	550	1400
Weight of heaviest reel, including cable	kg	4570	9770



ELECTRICAL DATA at 50Hz		
	0.1	0.1
Maximum D.C. conductor resistance at 20 °C	Ω/km	0.1 0.129
Maximum A.C. conductor resistance at 90 °C	Ω/km	
Maximum D.C. metallic screen resistance at 20 °C	Ω/km	0.177
Maximum D.C. aluminum foil resistance at 20 °C	Ω/km	0.614
Operating inductance	<b>TT</b> /1	0.45
<ul> <li>trefoil formation</li> <li>flat formation <sup>(*)</sup></li> </ul>	mH/km mH/km	0.45 0.635
Induction reactance		0.055
□ trefoil formation	Ω/km	0.141
□ flat formation <sup>(*)</sup>	$\Omega/km$	0.141
Capacitance	μF/km	0.138 (+ 8 %)
Capacitance reactance	kΩ/km	23.02
Impedance	KS2/KIII	23.02
□ trefoil formation	Ω/km	0.191
□ flat formation <sup>(*)</sup>	$\Omega/km$	0.238
Zero sequence reactance	$\Omega/km$	0.09
Max. electric stress at conductor screen / (at insulation)	kV/mm	6.91 / 2.64
Dielectric losses (tg $\delta = 0.001$ ) – per phase	W/m	0.251
Partial discharge test – at $1.5$ Uo	pC	<u>0.251</u> ≤5
Charging current – per phase	A/km	3.3
Charging power	kVA/km	251
Earth fault current – per phase	A/km	9.9
MECHANICAL DATA		
Recommended min. bending radius for laying	m	1.85
Recommended permissible bending radius for laying		1.05
installation	m	1.48
Maximum permissible pulling force:	kN	9
SHORT CIRCUIT CURRENTS		
Maximum permissible thermal short-circuit Current		
for 1.0 sec. (IEC 60949)		
Phase conductor $90 \rightarrow 250 \text{ °C}$	kA	28.8
Metallic screen $80 \rightarrow 350 ^{\circ}\text{C}$	kA	20.8
AMPACITY <sup>(**)</sup> – Bonding of the metallic screens		Single point
in earth		C L
$\Box$ flat formation <sup>(*)</sup>	А	500
□ trefoil formation	A	475
in air		
□ flat formation	А	630
trefoil formation	А	560
TESTS		
AC Test voltage – (2.5Uo; 30min)	kV	190
Partial discharge test	kV	114

#### Marking: TF-KABLE 5 A2XS(FL)2Y 1x300RM/105 76/132kV IEC 60840 2020

 $^{(\ast)}$  Distance between cable axes laid in flat formation  $D_e \! + \! D_e \, mm$ 

(\*\*) Current rating guideline (Calculated with CymCap 5.3 based on IEC Pub. 60287 and the following conditions)

- $\Box \quad \text{Ground temperature} \qquad 20 \text{ }^{\circ}\text{C}$
- □ Laying depth 1.0 m
- $\Box$  Ground thermal resistivity 1.0 K · m/W
- $\Box \text{ Load factor } 1.0$
- $\Box \quad \text{Air temperature} \qquad \qquad 35 \ ^\circ\text{C}$

Date: 2020-09-18; MK20186 Prepared by: Marcin Kocik

<sup>(x)</sup> Diameters are calculated values and subject to manufacturing tolerances